



EFFECTIS ERA AVRASYA TEST ve BELGELENDİRME AŞ
Dilovası OSB Mahallesi Fırat Caddesi No: 18
Dilovası, Kocaeli / TÜRKİYE
www.effectis.com

DECLARATION OF TEST RESULTS

No: ERA – 2400-0025

ASTM E84 test method was carried out for the product as described below at Efectis Era Avrasya
Test Laboratory on December 15th, 2024.

SEMIAFS (Thickness: 90 μm / Density: 2,71 g/cm³)

| | |
|---------------------|------------|
| FSI [ft.min] | 5,0 |
| SDI [%min] | 0,0 |

| |
|--------------|
| Class |
| A |

Placed on the market by: AFS BORU SANAYİ A.Ş.
Kuşkondu Sokak No:1 1 Çankaya, Ankara / TÜRKİYE

Manufactured by: AFS BORU SANAYİ A.Ş.
İvedik O.S.B. Havalandırmacılar Cadde No:153 Yenimahalle,
Ankara / TÜRKİYE

e-signed

Ali BAYRAKTAR
Laboratory Manager
16.01.2025

This document is a declaration of test results and does not represent any type of approval or certification of the product. All details related to product specifications and field of applications are described in the report no: FTST25044.

