



Classification of Reaction to Fire Performance According to EN 13501-1:2018

Registration No: 100523.CER.01

Issue Date: May 10, 2023

Manufacturer : **AFS BORU SANAYI A.S.**
Ivedik O.S.B. Havalandirmacılar. Cad. No: 153 Ostim 06370
Ankara / Turkey

Product Name : SEMIAFS

Product Description : Semi flexible air duct comprising 1 layer aluminium
secured using an interlock system

This certificate reports the classification assigned to SEMIAFS in line with the procedures given in EN 13501-1:2018.

Reaction to fire classification: A1

A blue ink signature, likely of Seyhan KARAKURT, written over a horizontal line.

Authorized by :

Seyhan KARAKURT
Laboratory Manager